



NOTES:

1. ABOVE METHODS ARE TO BE USED WHEN INSUFFICIENT COVER EXISTS TO ALLOW PRESSURE PIPE TO CROSS
2. ABOVE CONFLICT PIPE WITH 6" MIN. VERTICAL SEPARATION & MAINTAIN 36" COVER TO FINISHED GRADE.
3. FITTINGS SHALL BE RESTRAINED JOINT MEGALUGS.
4. DO NOT EXCEED 75% OF MANUFACTURERS RECOMMENDED MAXIMUM JOINT DEFLECTION, WHEN APPROVED BY A VOLUSIA COUNTY REPRESENTATIVE.
5. SEE TYPICAL PIPE CROSSING DETAIL.

PIPE CONFLICT DETAIL