


SINGLE SET, METER SET FOR 5/8", 3/4" AND 1" METERS

SINGLE SERVICE SET (WATER AND RECLAIM)




NO POLYTUBING UNDER ROAD ALLOWED WITHOUT 2" CASING

1. 1" TAPPING SADDLE CC THREAD, EPOXY COATED WITH STAINLESS STEEL STRA.
2. 1" CORPORATION STOP FORD FB1000-4-G (1" BALLVALVE, INLET, OUTLET) MUELLER EQUAL.
3. 1" CURB STOP, FORD B43-342W-NL (3/4" VALVE, 1" INLET PE END PACK JOINT-CTS, MUELLER EQUAL (THIS IS FOR 5/8" AND 3/4" METER SET). IF 1" METER SET USE FORD CURB STOP B41-344W-NL.
4. 1" 200 PSI, SDR 9 ENDOT ENOPURE BLUE WATER SERVICE TUBING (POTABLE), PURPLE (RECLAIMED) WITH TRACER WIRE AND SNAKE BITE CONNECTORS.
5. 2" PVC SCHEDULE 40, CASING PIPE WHITE, IF INSTALLATION UNDER ROAD (PAVED OR DIRT).

DOUBLE SET OR DUAL SET

METER SET FOR 5/8" AND 3/4" METERS (WATER ONLY)




NO POLYTUBING UNDER ROAD ALLOWED WITHOUT 2" CASING

1. 1" TAPPING SADDLE CC THREAD, EPOXY COATED WITH STAINLESS STEEL STRAP.
2. 1" CORPORATION STOP FORD FB1000-4-G (1" BALLVALVE, INLET, OUTLET) MUELLER EQUAL.
3. 1" X 3/4" U BRANCH PACK JOINT-CTS FORD U48-43-NL 7.5 OR MUELLER H1460.
4. 3/4" CURB STOP, FORD B13-332W-NL OR MUELLER EQUAL.
5. 1" 200 PSI, SDR 9 ENDOT ENOPURE BLUE WATER SERVICE TUBING (POTABLE), PURPLE (RECLAIMED) WITH TRACER WIRE AND SNAKE BITE CONNECTORS.
6. 2" PVC SCHEDULE 40, CASING PIPE WHITE, IF INSTALLATION UNDER ROAD (PAVED OR DIRT).

2" WATER SERVICE CONNECTION FOR 1 1/2" AND 2" METER SETS

(WATER AND RECLAIM)



NO POLYTUBING UNDER ROAD ALLOWED WITHOUT 4" CASING

1. 2" TAPPING SADDLE CC THREAD, EPOXY COATED WITH STAINLESS STEEL STRAP,
2. 2" CORPORATION STOP FORD FB1101-7-G (2" BALLVALVE X IPT X CTS) MUELLER EQUAL..
3. 2" CURB STOP, BF43-777W-NL (2" VALVE, 2" CTS X 2" FLANGE) FLANGE WILL FIT 1 1/2" OR 2" FLANGE WATER METER.
4. 2" 200 PSI, SDR 9 ENDOT ENOPURE BLUE WATER SERVICE TUBING (POTABLE), PURPLE (RECLAIMED) WITH TRACER WIRE AND SNAKE BITE CONNECTORS.
5. 4" PVC SCHEDULE 40, CASING PIPE WHITE, IF INSTALLATION UNDER ROAD (PAVED OR DIRT).

WATER & RECLAIMED SERVICE DETAIL