



NOTES

1. DRAWING IS SHOWN FOR 230 VOLT POWER SUPPLY. THE ELECTRICAL UTILITY SHALL DETERMINE THE SERVICE CONFIGURATION.
2. POWER SUPPLY SHALL BE UNDERGROUND ON THE LIFT STATION SITE AND SHALL BE 3 PHASE FROM A 3 PHASE SOURCE ONLY.

CONTROL PANEL/ ANTENNA ELEVATION

N.T.S.