



NOTES:

1. SEE LIFT STATION DETAIL SHEET FOR EQUIPMENT AND STRUCTURE DESIGN.
2. ENGINEER SHALL PROVIDE A SCALED (1"=20' MIN.) SITE SPECIFIC DETAIL.
3. THE HOA OR OTHER PRIVATE ENTITY SHALL BE RESPONSIBLE FOR MAINTENANCE IF LANDSCAPING IS INSTALLED.
4. LIFT STATION SITE TO BE GRADED TO DRAIN AWAY FROM WET WELL.
5. DRIVEWAY AND GENERATOR PAD FINISHED ELEVATION TO BE 0.1 TO 0.2 FEET BELOW TO OF WET WELL WITHIN FENCED AREA, WITH POSITIVE DRAINAGE AWAY FROM WET WELL.
5. GRADING OF SITE OUTSIDE OF FENCE SHALL NOT EXCEED 4:1 SLOPE.

LIFT STATION SITE PLAN