



NOTES:

1. THE CONTRACTOR SHALL CONTACT THE UTILITIES INSPECTOR FOR EXACT METER ASSEMBLY LENGTH AND HEIGHT REQUIREMENTS. THE CONTRACTOR SHALL PROVIDE AND INSTALL ALL PIPE, FITTINGS, METER ASSEMBLY AND APPURTENANCES. ALL ABOVE GROUND PIPE SHALL BE FLANGED DUCTILE IRON, PRIMER COATED ONLY.
2. ALL FLANGES: PIPE, VALVES AND APPURTENANCES SHALL BE IN ACCORDANCE WITH VCU'S LIST OF MATERIAL AND APPROVED MANUFACTURES.
3. FINISH GRADE AROUND METER ASSEMBLY SLAB SHALL ENSURE A SAFE WORK ENVIRONMENT. GRADING SLOPE DROP OFF SHALL NOT EXCEED 6-IN WITHIN 5-FT OF SLAB.
4. SENSUS OMNI METER WITH RADIO READ CAPABILITY
5. F-2 STRAINER REQUIRED FOR FIRE FLOW
6. PIPE SUPPORT TO BE BOLTED TO THE FLANGE. PIPE SUPPORTS APPLY TO ENTIRE ABOVE-GROUND ASSEMBLY, INCLUDING THE MAIN AND BYPASS PIPING.
7. FOR RECLAIMED WTER METERS, BYPASS AND BACKFLOW PREVENTER NOT REQUIRED.
8. BOLLARDS REQUIRED AT DISCRETION OF VOLUSIA COUNTY.

4" AND LARGER MASTER METER ASSEMBLY WITH ABOVE-GROUND BYPASS