



- NOTES:
1. ALL PIPE & FITTINGS ABOVE GRADE SHALL BE FLANGED
 2. ALL PIPING, FITTINGS AND SUPPORTS TO BE PAINTED. COLOR TO BE SELECTED BY COUNTY.
 3. DOUBLE DETECTOR CHECK ASSEMBLY SHALL HAVE A FUSED EPOXY COATED CAST IRON BODY.
 4. ASSEMBLY SHALL BE EQUIPPED WITH A LOW FLOW METERING DEVICE TO DETECT LEAKS.

DOUBLE DETECTOR CHECK ASSEMBLY

FOR FIRE PROTECTION ONLY