



NOTES:

1. FIRE HYDRANT TO BE LOCATED 5' TO 10' FROM EDGE OF PAVEMENT.
2. VALVE BOX SHALL BE SCREW TYPE ADJUSTABLE AND COVER SHALL BE MARKED: WATER.
3. FIRE HYDRANTS CANNOT BE LOCATED WITHIN THE RADIUS OF STREET CORNERS.
4. ABOVE GROUND OBSTRUCTIONS MAY BE LOCATED NO CLOSER THAN 3' FROM FIRE HYDRANTS.
5. FIRE HYDRANT SHALL BE SUPPLIED WITHOUT WEEP HOLE, OR WITH A PERMANENTLY PLUGGED WEEP HOLE.
6. FIRE HYDRANT SHALL COMPLY VOLUSIA COUNTY SPECIFICATIONS, APPENDIX A, LIST OF APPROVED MANUFACTURERS AND MATERIALS.
7. ALL FIRE HYDRANT PIPING SHALL BE RESTRAINED BY MEGA-LUGS.
8. LOCATE WIRE AND LOCATE TAPE SHALL BE INSTALLED ON ALL PIPES.
9. A BLUE REFLECTOR SHALL BE INSTALLED ON THE PAVEMENT ADJACENT TO THE FIRE HYDRANT.

FIRE HYDRANT ASSEMBLY DETAIL

N.T.S.